



Commercial Kitchen Solid Fuel Chimney System Cleaning and Inspection Report

REQUIRED DOCUMENTATION

Contractor shall submit to the Vancouver Fire Marshal within 30 days of the on-site service date. Submittal is mandatory in accordance with VMC 16.04

Endorsed Contractor Company Name:		Endorsed Technician Name:	
--	--	----------------------------------	--

Customer/Business Name:		Location Address:	
System Owner Name:	Telephone:	Email:	

Associated Exhaust Hood Bar Code(s):		Service Date:	
---	--	----------------------	--

NFPA 211 Inspection Level	Level 1	Readily accessible areas of chimney, structure, and flue; lack of obstruction or combustible deposits in flue; basic appliance installation and connection
	Level 2	All subjects of a Level I inspection; proper construction and condition of accessible portions of the chimney structure and all enclosed flues; proper clearances from combustibles in accessible locations; size and suitability of flues for connected appliances
	Level 3	All subjects of Level I and Level II inspections; proper construction and condition of concealed portions of chimney structure and enclosed flues; proper clearances from combustibles

Estimated Cooking Volume	<input type="checkbox"/> High <input type="checkbox"/> Medium <input type="checkbox"/> Low	Chimney Terminus:	<input type="checkbox"/> Roof Top <input type="checkbox"/> Wall
Cooking Fuel	<input type="checkbox"/> Gas <input type="checkbox"/> Electric <input type="checkbox"/> Solid Fuel <input type="checkbox"/> Other:	Cooking Type:	<input type="checkbox"/> Deep Fryer <input type="checkbox"/> Grill <input type="checkbox"/> Wok <input type="checkbox"/> Char broiler <input type="checkbox"/> Pizza Oven <input type="checkbox"/> Other:

Inspection	Problem noted, repair scheduled or completed	Problem noted, repair not scheduled or completed	Clean, undamaged	N/A
Inspection door access				
Flue deposits, damage, or obstruction present?				
Chimney connector supports, bracing and pitch adequate?				
Internal surfaces and lining material clean/undamaged?				
Connection of exhaust to chimney uncompromised?				
Changes to fuel source since last inspection?				
Access adequate, attics, rooftop, appliance connections?				
Flue sizing sized appropriately?				
Chimney fire damage?				
Evidence that the chimney is not operating as intended?				



Chimney fully inspected and clean?				
Digital image scanning used?				

Use additional forms for chimneys. Attach before and after photos

Contractor: Submit a copy of this report through the Endorsed Contractor Portal to the Vancouver Fire Marshal within 30 days of date of inspection/service. Any repairs or updates should be uploaded as an update to this report.

I certify that the above information is true and accurate as of the service date (s) listed above:

Endorsed Technician Signature: _____ Date of Signature: _____

System Owner: Maintain a copy of this report on the premises for a minimum of six (6) years.

System Owner Signature: _____ Date of Signature: _____

Photos before and after cleaning

Before	After
Before	After
Before	After



Before	After
Before	After
Before	After
Before	After



Before	After
Before	After
Before	After
Before	After



Before	After
Before	After
Before	After
Before	After



--	--