

Means of Egress Illumination Verification and Test Report



Verification & Test Report

Means of egress illumination system for the referenced project has been provided and tested to verify compliance and meets current adopted code requirements.

Test Date: _____ Test Conducted By: _____

Project Electrical Contractor/License #: _____

Contractor's Signature: _____

Project Address: _____ CMI- _____

Means of Egress Illumination Requirements

IBC 1008.2: The means of egress shall be illuminated at all times

IBC 1008.2.1: Means of egress illumination not less than 1 footcandle at walking surface, exit stairs not less than 10 footcandles

IBC 1008.3.1: Emergency electrical system shall illuminate aisles, corridors and exit stairs/ramps

IBC 1008.3.3: Emergency electrical system shall illuminate electrical rooms, fire command centers, fire pump rooms, generator rooms and public restrooms with an area greater than 300 square feet

IBC 1008.3.4: Emergency power shall be provided for a duration of not less than 90 minutes

IBC 1008.3.5: Emergency lighting shall provide an initial average of 1 footcandle at floor level

Before/After Hours Inspection by City Building Inspector is required for:

- All schools, colleges, hospitals
- 4+ story buildings all occupancies
- Child care centers with occupant load exceeding 50
- Hotels, congregate dwelling units, night clubs, theaters, restaurants/bars with occupant load exceeding 100
- Churches, gymnasiums and mercantile occupancies with occupant load exceeding 300

[Before/After Hours Inspection Request](#)